

August 25, 2006

INTERNATIONAL PRODUCTION SPECIALISTS
JAY BANDHOLZ
35006 WASHINGTON AVE
PO BOX 125
HONEY CREEK WI 53138

Re: Description: SEWAGE TANKS, STEEL
Manufacturer: INTERNATIONAL PRODUCTION SPECIALISTS
Product Name: HOLDING OR PUMP
Model Number(s): 2500 / H2500A
(47" L.L., 72" MAX. DEPTH OF BURY)
Product File No: 20060386

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2011.

This approval is contingent upon compliance with the following stipulation(s):

- The products produced by this manufacturer are approved to use the following:
 - Bolt on anodes.
 - One inch opening for electrical connections.
 - Internal support rings spaced evenly along tank.
 - Optional 6", 8", or 10" threaded plug in access cover.
 - Flip top access cover or bolt down cover with or without gasket.
 - 3" diameter suction pump extension with coupling.
 - 2" opening for vent connection.
 - 4", 6" or 8" inlet and/or outlet.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010327.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658; 201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov